



Mossel Bay

MUNICIPALITY

MOSSSEL BAY | HARTENBOS | GREAT BRAK RIVER | HERBERTSDALE



www.mosselbay.gov.za



admin@mosselbay.gov.za



Fax/ifeksi: +27 (44) 606 5062



Tel/ Imfonomfono: +27 (44) 606 5000

In antwoord verwys na nommer
In reply quote number 15/1/1/3 Elouw
Xa Uphendula chaza Le Nombolo

Cape EAPrac

17 Progress Street

George

Po. Box 2070

George

6530

12 October 2023

Attention: Mariska Byleveld

CONFIRMATION OF CAPACITY WITHIN THE MUNICIPAL WATER AND SANITATION SERVICES.

We accept the suggestion of conservancy tank for the internal sewer for the development. We are in the process of attending to the challenges at the Cricket Field pumpstation. The Great Brak Waste Water Treatment Plant is current being upgraded and there is sufficient capacity to deal with the sewage volumes from this development.

We accept your suggestion with regards to the internal water reticulation for the development.

The available storage capacity of the water reservoir must be determined by GLS. The developer will be responsible for the cost for the report from GLS. Please contact Mr. Paul Malherbe at GLS.

Paul Malherbe
Stellenpark, Block D North
Cnr of R44 and School Rd
Jamestown Po Box 814
Stellenbosch
7599
Paul@gls.co.za ; flip.duplessis@gls.co.za

Kind Regards

E. Louw
Senior Manager: Water and Sanitation

MOSSSEL BAY | HARTENBOS | GREAT BRAK RIVER | HERBERTSDALE

101 Marshstraat Street Sitalato 101
Privaatsak Private Bag Ingxowa Yeposi Ngu X29
Mosselbaai Mossel Bay Bayi 6500



Mossel Bay

M U N I C I P A L I T Y
MOSEL BAY | HARTENBOS | GREAT BRAK RIVER | HERBERTSDALE



www.mosselbay.gov.za



admin@mosselbay.gov.za



Fax/ifeksi: +27 (44) 606 5062



Tel/Imfonomfono: +27 (44) 606 5000

In antwoord verwys na nommer
In reply quote number
Xa Uphendula chaza Le Nombolo

16/2/1//P Harmse
C9953061

03 July 2023

By e-mail: rsteenekamp@cmbgeorge.co.za

CMB Consulting Engineers
39 Victoria Street
GEORGE
6529

Attention: Mr. R Steenekamp

Dear Sir,

APPLICATION FOR AN ELECTRICAL SUPPLY POINT: ERF 2833, GREAT BRAK RIVER, MOSSEL BAY.

Your application dated 28 June 2023 refers.

We hereby approve your application for an electrical connection to the capacity of 173.2kVA for the development on Erf 2833, Great Brak River, Mossel Bay on the following conditions:

- a) Development contributions is payable at the ruling rate.
- b) Applicable connection deposit is payable.
- c) A wayleave application for existing services shall be submitted to the Department Infrastructure Services prior to commencement of construction. Payment of the wayleave application shall be done as per the ruling tariff.
- d) The bulk meter shall be installed and commissioned by a municipal appointed service provider for bulk metering.
- a) A SL7000 bulk meter with Automatic Meter Reading (AMR) function shall be installed in the LV metering kiosk at the boundary of the development.
- b) The LV cable up to the metering kiosk shall be PVC insulated, PVC bedded, Galvanised steel wire armoured 600/1000V with copper conductors.
- c) Internal LV reticulation will not be taken over by Mossel Bay Municipality.
- d) The miniature substation and LV reticulation up to the metering kiosk will be taken over by Mossel Bay Municipality.

Yours faithfully

S NAIDOO
DIRECTOR: INFRASTRUCTURE SERVICES

MOSEL BAY | HARTENBOS | GREAT BRAK RIVER | HERBERTSDALE

101 Marshstraat Street Sitalato 101
Privaatsak Private Bag Ingxowa Yeposi Ngu X29
Mosselbaai Mossel Bay Bayi 6500